

Customer	Class	File Number
Kuo Yuh Enterprise Co. No. 17 Ke Chia 6th Road, Tou Liu City Youn Lin County Taiwan 64057	3215-30 SUPPLEMENTARY PROTECTORS-COMPONENT ACCEPTANCE PROGRAM	102199_0_000

NOTE: PRODUCTS EVALUATED TO CSA NOTICE N04-042.

Supplementary Protector, thermal trip, manual reset, without manual switching feature:

- Model F88-1500, rated 15A, 125V ac; Model F88-1300, rated 13A, 125V ac;

Application Codes: TC2, OL0, SC: C1, 1kA, 125V ac (4In Series fuse)

Supplementary Protector, thermal trip, single pole, auto reset:

- Model F66, rated 0.5A to 5A, 125V ac;

Application Codes: TC2, OL0, SC: C1, 0.2kA, 125V ac (4In Series fuse)

Supplementary Protector, thermal trip, manual reset, without manual switching feature:

- Series 88, rated 15A, 125V ac and 10A, 125V ac/50V dc;

Application Codes: TC2, OL0, SC: C1, 1kA, 125V ac and SC: C1, 0.03 kA, 50V dc (4In Series fuse)

Supplementary Protector, thermal trip, manual reset:

- Series 88, rated 3A to 16A, 125 V ac;

Application Codes: TC1, OL1, SC: U3, 0.4KA, 125V ac

Supplementary Protector, thermal trip, manual reset:

- Series 98, rated 3A to 30A, 125 V ac;

Application Codes: TC1, OL1, SC: U3, 0.4KA, 125V ac

Notes:

- Accepted only for use as components of other certified assemblies where the suitability is determined by CSA International.
- The F66 devices are intended to be mounted on printed wiring boards.
- The terminals of the device have not been investigated for field wiring.
- These devices are not suitable for branch circuit overcurrent protection.
- All short circuit testing was conducted with series protection rated 20 A for F66 Series.
- Cat No 88, rated 15 A and 10 A, 125 V ac, has a short circuit withstand rating of 1000 A.
- Cat No 88, rated 10 A, 50 V dc, has a short circuit withstand rating of 30 A.