

IEC**IECEE
CB
SCHEME**

Ref. Certif. No.

CN29746

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST
CERTIFICATES FOR ELECTRICAL EQUIPMENT (IECEE)
CB SCHEMESYSTEME CEI D'ACCEPTATION MUTUELLE DE
CERTIFICATS D'ESSAIS DES EQUIPEMENTS
ELECTRIQUES (IECEE) METHODE OC**CB TEST CERTIFICATE**Product
Produit

Circuit-breaker for Equipment

Name and address of the applicant
Nom et adresse du demandeurKUOYUH W.L. ENTERPRISE CO.,LTD.
No.17 Kejia 6th Road, Douliu City, YunLin, Taiwan, P.R.ChinaName and address of the manufacturer
Nom et adresse du fabricantKUOYUH (Dongguan) Enterprise Co.,Ltd.
No.4 Donghuan Road, Tianmei Village, Huangjiang Town,
Dongguan City, Guangdong Province, P.R.ChinaName and address of the factory
Nome et adresse de l'usineKUOYUH (Dongguan) Enterprise Co.,Ltd.
No.4 Donghuan Road, Tianmei Village, Huangjiang Town,
Dongguan City, Guangdong Province, P.R.ChinaNote: When more than one factory, please report on page 2
Note: Lorsque plus d'une usinem, veuillez utiliser la 2^{me} pageRatings and principal characteristics
Valeurs nominales et caractéristiques principales

See the Appendix

Trademark (if any)
Marque de fabrique (si elle existe)

KUOYUH

Model / Type Ref.
Ref. De type

91 Series,92 Series,88A Series,F88 Series

Additional information (if necessary may also be reported
on page 2)
Les informations complémentaires (si nécessaire, peuvent être
indiqués sur la 2^{me} page)**PUBLICATION EDITION**A sample of the product was tested and found
to be in conformity with
Un échantillon de ce produit a été essayé et a été
considéré conforme à laIEC 60934:2000(Third Edition)+Amendment
1:2007+Amendment 2:2013As shown in the Test Report Ref. No. which forms part
of this Certificate
Comme indiqué dans le Rapport d'essais numéro de
référence qui consttite partie de ce Certificat

GQI-CONT-2014001

This CB Test Certificate is issued by the National Certification Body
Ce Certificat d'essai OC est établi par l'Organisme **National de Certification****CHINA QUALITY CERTIFICATION CENTRE**

Date: 2014-03-20

Signature: Wang Kejiao

Issued 2003-05
China Quality Certification Centre
Section 9, No.188, Nansihuan Xilu, Beijing 100070 P.R.ChinaTel: +86-10-83886666
Fax: +86-10-83886282website
www.cqc.com.cn

CB 0024937

IEC**IECEE**
CB
SCHEME

Ref. Certif. No.

CN29746

91 Series,92 Series,88A Series,F88 Series

Ue:AC125/250V

In:

91 Series:

0.5A,0.75A,0.8A,1.0A,1.25A,1.5A,1.6A,1.75A,2.0A,2.2A,2.5A,2.75A,
3.0A,3.15A,3.3A,3.5A,4.0A,4.5A,5.0A,6.0A,6.3A,6.5A,7.0A,7.5A,8.0A,
9.0A,10.0A;

92 Series:

0.5A,0.75A,1A,1.25A,1.5A,1.75A,2A,2.5A,3A,3.5A,4A,5A,6A,7A,8A,9A,10
A,11A,12A,13A,14A,15A,16A;

88A Series:

3A,4A,5A,6A,7A,8A,9A,10A,11A,12A,13A,14A,15A,16A;

F88 Series:

3A,4A,5A,6A,7A,8A,9A,10A,11A,12A,13A,14A,15A,16A

Incl=500A;

Method of operation: Type R;

1P

Additional information (if necessary)

Information complémentaire (si nécessaire)

Date: 2014-03-20

Signature:



Wang Kejiao