



A P P R O V A L S ®

Certificate of Suitability

Certificate No.: SAA192475

Certificate Holder: KUOYUH W.L. Enterprise Co.,Ltd.
No.17, Kejia 6th Road,
Douliu City Yunlin 64057
Taiwan

Class Description: Non-Declared
Product Description: Circuit Breaker for Equipment
(Flush-type or panel-mounting, S type)

Trade Name: KUOYUH
Model No.: 94a-b-cdef Series
Markings: 125/250V, 50/60Hz Uim 1.5kV
PC1 1kA

Standard: In: 4.0A-16.0A
Conditions: IEC 60934 Ed. 3.2
Nil

Certification Mark: SAA192475 or RCM

Date First Registered: 18 September 2019
Date of Expiry: 18 September 2024

For and on Behalf of
SAA Approvals Pty Ltd

SAA Approvals Pty Ltd certifies that the product nominated in this certificate complies with standard/s listed.

When using the RCM the requirements of all relevant parts of AS/NZS 4417 applicable to the article must be fulfilled.

For SAA Contact Details and to verify this Certificate go to:
www.saaapprovals.com.au



Issued: 18-09-19 192475/1