



A P P R O V A L S ®

Certificate of Suitability

Certificate No.: SAA173169

Certificate Holder: KUOYUH W.L. Enterprise Co.,Ltd.
No.17, Kejia 6th Road, Douliu City
Yunlin 64057
Taiwan

Class Description: Non-Declared
Product Description: Circuit-breaker (For equipment, flush type
or panel-mounting type)

Brand Name: KUOYUH

Model No.: 98 series

Markings: 125/250V, 50/60Hz U_{im} 1.5kV

PC1 1kA

$I_n =$ 3, 3.25, 3.3, 3.5, 3.75, 4, 4.25, 4.5, 4.75, 5,
5.25, 5.5, 5.75, 6, 6.25, 6.5, 6.75, 7, 7.25, 7.5,
7.75, 8, 8.25, 8.5, 8.75, 9, 9.25, 9.5, 9.75, 10,
10.25, 10.5, 10.75, 11, 11.25, 11.5, 11.75, 12,
12.25, 12.5, 12.75, 13, 13.25, 13.5, 13.75, 14,
14.25, 14.5, 14.75, 15, 16, 17, 18, 19, 20, 21,
22, 23, 24, 25, 26, 27, 28, 29, 30A

TO, R Type, Cycling Trip Free

Standard: IEC 60934 Ed 3.2

Conditions: Nil

Certification Mark: SAA173169 or RCM

Date First Registered: 9 January 2018

Date of Expiry: 9 January 2023


For and on Behalf of
SAA Approvals Pty Ltd

SAA Approvals Pty Ltd as accredited by JAS-ANZ under ISO/IEC 17065 certifies in accordance with the SAA Approvals Electrical Product Safety Certification Scheme that the product nominated in this certificate complies with standard/s listed.

When using the RCM the requirements of all relevant parts of AS/NZS 4417 applicable to the article must be fulfilled.

For SAA Contact Details and to verify this Certificate go to:
www.saaapprovals.com.au

JAS-ANZ



www.jas-anz.org/register



Issued: 09-01-18 173169/1